

DAVID W. KANE, EXECUTIVE DIRECTOR

Indiana Department of Homeland Security Indiana Government Center South 302 West Washington Street Indianapolis, IN 46204 317-232-3980

March 5, 2015

BRYAN DUNCAN INDIANA STATE UNIVERSITY 951 SYCAMORE ST

TERRE HAUTE, IN 47809

Dear BRYAN DUNCAN,

This letter provides notice below of the action taken by the Fire Prevention and Building Safety Commission on your application(s) for a variance(s) from the Commission's rules under IC 22-13-2-11 and 675 IAC 12-5. The Commission considered the application with all alternatives offered, as a part of its published agenda, at its regular meeting on March 3, 2015.

Project Number	Project	Name	Variance Number
	INDIANA	STATE UNIVERSITY BLUMBERG HALL	15-01-18
Commission Condit	ions		

Egress lighting shall be installed throughout halls.

Edition Code	Code Section	Commission Action & Date
GAR	Rule 4, Sec 12(f)	Approved as 03/03/2015 submitted
IN BC (675 IAC 13-2.6)	403	Approved with 03/03/2015 Commission condition(s)
IN BC (675 IAC 13-2.6)	708.6, 716	Approved as 03/03/2015 submitted
IN BC (675 IAC 13-2.6)	1018.1	Approved as 03/03/2015 submitted
IN BC (675 IAC 13-2.6)	716.5.9	Approved as 03/03/2015 submitted
IN BC (675 IAC 13-2.6)	1008.1.9.11, exc 6	Approved as 03/03/2015 submitted

You are advised that if you desire an administrative review of this action, you must file a written petition for review at the above address with the Fire Prevention and Building Safety Commission. Your petition must fully identify the matter for which you seek review no later than eighteen(18) calender days from

the above stated date of this letter, unless such date is a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security's offices are closed during regular business hours; in which case the deadline would be the first day thereafter that is not a Saturday, Sunday, legal holiday under state statute, or day that the Department of Homeland Security's offices are closed during regular business hours. If you do so, your petition for review will be granted and an administrative proceeding will be conducted by an administrative law judge appointed by the Fire Prevention and Building Safety Commission. If you do not file a petition for review, this action will be final. Please be further advised that you may request an opportunity to informally discuss this matter prior to filing a petition for review. Such informal discussion, or request therefore, does not extend the deadline for filing a petition for review and, therefore, any request for an informal discussion should be made promptly, preferably by telephone or e-mail, upon receipt of this letter.

Sincerely,

Pamela M, Walters

Legal & Code Services,

Department of Homeland Security